

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0694:209 Page 1 of 1

CATEGORY: Fire Alarm Devices for Hearing Impaired

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna *(781) 471-3000

DESIGN: Models S1215, S2415, *S2430, S2475, S24110, S121575, and *S241575 strobe lights, followed by suffix –FC. May also be followed by suffix –W indicating color white. *Model S241575 may also have suffix –F, -EV, or _AG. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Electrical: -12: 10.5 - 17 VDC
-24: 20 - 30 VDC
Candela: -15: 15 cd
-1575: 15 cd, 75 cd on axis
*-30: 30 cd
-75: 75 cd
-110: 110 cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and candela rating and UL label.

APPROVAL: Listed as hearing impaired strobe lights for use with separately listed compatible fire alarm control unit. For **wall mount** and **indoor** use only.

XLF: 7135-1209:174

*Rev 06-16-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager